



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: Deron School I
 1140 Commerce Ave
 -

APL Order ID Number: 6070468
 Collected : 07/19/2016 6:43
 Received: 07/19/2016

Contact:
 Report Date: 07/31/2016 9:58

Client Project: Deron School I
 Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
6070468-01	Drinking Water	Room 100 WF Low						
Total Metals								
Lead	EPA 200.8	7/20/16 13:17	7/20/16 13:17	< 0.00200			0.00200	mg/L
6070468-02	Drinking Water	Main Office Pantry						
Total Metals								
Lead	EPA 200.8	7/20/16 13:23	7/20/16 13:23	< 0.00200			0.00200	mg/L
6070468-03	Drinking Water	WF Main Hall High						
Total Metals								
Lead	EPA 200.8	7/20/16 13:29	7/20/16 13:29	< 0.00200			0.00200	mg/L
6070468-04	Drinking Water	Art Room						
Total Metals								
Lead	EPA 200.8	7/20/16 13:35	7/20/16 13:35	0.00251			0.00200	mg/L
6070468-05	Drinking Water	Staff Room						
Total Metals								
Lead	EPA 200.8	7/20/16 13:41	7/20/16 13:41	< 0.00200			0.00200	mg/L
6070468-06	Drinking Water	Kitchen Main Sink						
Total Metals								
Lead	EPA 200.8	7/20/16 13:47	7/20/16 13:47	< 0.00200			0.00200	mg/L

Brian Wood
 Laboratory Director

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
6070468-07	Drinking Water	WF Outside Gym High						
Total Metals								
Lead	EPA 200.8	7/20/16 13:53	7/20/16 13:53	< 0.00200			0.00200	mg/L
6070468-08	Drinking Water	Gym Boys Room Low						
Total Metals								
Lead	EPA 200.8	7/20/16 13:59	7/20/16 13:59	< 0.00200			0.00200	mg/L
6070468-09	Drinking Water	Kens Office						
Total Metals								
Lead	EPA 200.8	7/20/16 14:05	7/20/16 14:05	< 0.00200			0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 U or ND - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns.

Brian Wood
 Laboratory Director

