



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: Deron School- Montclair
 130 Grove Street
 Montclair, NJ

APL Order ID Number: 7040681
 Collected : 04/22/2017 7:21
 Received: 04/24/2017

Contact:
 Report Date: 05/08/2017 13:28

Client Project: Deron School- Montclair
 Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
7040681-01	Drinking Water	#001 Kitchen Back Sink						
Total Metals								
Lead	EPA 200.8	4/25/17 20:29	4/25/17 20:29	< 0.00200			0.00200	mg/L
7040681-02	Drinking Water	#002 Kitchen Front Sink						
Total Metals								
Lead	EPA 200.8	4/25/17 20:34	4/25/17 20:34	< 0.00200			0.00200	mg/L
7040681-03	Drinking Water	#003 Basement WF Northside						
Total Metals								
Lead	EPA 200.8	4/25/17 20:39	4/25/17 20:39	< 0.00200			0.00200	mg/L
7040681-04	Drinking Water	#004 WF New Section Basement						
Total Metals								
Lead	EPA 200.8	4/25/17 20:44	4/25/17 20:44	< 0.00200			0.00200	mg/L
7040681-05	Drinking Water	#005 WF Basement Southside						
Total Metals								
Lead	EPA 200.8	4/25/17 21:04	4/25/17 21:04	< 0.00200			0.00200	mg/L
7040681-06	Drinking Water	#006 Room #250						

Brian Wood
 Laboratory Director

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
7040681-06	Drinking Water	#006 Room #250						
Total Metals								
Lead	EPA 200.8	4/25/17 21:09	4/25/17 21:09	0.00493			0.00200	mg/L
7040681-07	Drinking Water	#007 WF 2nd Floor Northside						
Total Metals								
Lead	EPA 200.8	4/25/17 21:14	4/25/17 21:14	0.00205			0.00200	mg/L
7040681-08	Drinking Water	#008 New Bldg Pantry						
Total Metals								
Lead	EPA 200.8	4/25/17 21:20	4/25/17 21:20	< 0.00200			0.00200	mg/L
7040681-09	Drinking Water	#009 Room #290						
Total Metals								
Lead	EPA 200.8	4/25/17 21:25	4/25/17 21:25	0.00279			0.00200	mg/L
7040681-10	Drinking Water	#010 WF 2nd Floor Southside						
Total Metals								
Lead	EPA 200.8	4/25/17 21:30	4/25/17 21:30	< 0.00200			0.00200	mg/L
7040681-11	Drinking Water	#011 Teacher's Room 3rd Floor						
Total Metals								
Lead	EPA 200.8	4/25/17 21:35	4/25/17 21:35	< 0.00200			0.00200	mg/L
7040681-12	Drinking Water	#012 WF Northside 3rd Floor						
Total Metals								
Lead	EPA 200.8	4/25/17 21:40	4/25/17 21:40	< 0.00200			0.00200	mg/L
7040681-13	Drinking Water	#013 Room #370						
Total Metals								
Lead	EPA 200.8	4/25/17 21:45	4/25/17 21:45	< 0.00200			0.00200	mg/L
7040681-14	Drinking Water	#014 WF Southside 3rd Floor						
Total Metals								
Lead	EPA 200.8	4/25/17 21:50	4/25/17 21:50	< 0.00200			0.00200	mg/L

Brian Wood
Laboratory Director



Analytical Results Summary

7040681-15 Drinking Water

#015 High WF New
Basement

Total Metals

Lead	EPA 200.8	4/25/17 22:10	4/25/17 22:10	< 0.00200	0.00200	mg/L
------	-----------	---------------	---------------	-----------	---------	------

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
U or ND - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns.

Brian Wood
Laboratory Director

